



**Environmental  
Protection Agency**

**John R. Kasich, Governor**

**Mary Taylor, Lt. Governor**

**Scott J. Nally, Director**

February 28, 2012

RE: ASHTABULA COUNTY  
CITY OF CONNEAUT  
CITY OF CONNEAUT EAST SIDE  
INDUSTRIAL PARK  
NPDES PERMIT NO. OHR000004  
OHIO EPA PERMIT NO. 3GC04614\*AG  
CONSTRUCTION STORM WATER

Bob Howland  
294 Main Street  
Conneaut, OH 44030

Dear Mr. Howland:

On January 30, 2012, Ohio EPA conducted an inspection of City of Conneaut East Side Industrial Park, located on U.S. Route 20, Opposite of Thompson Road, City of Conneaut, Ashtabula County (site). Ohio EPA records indicate that the site is covered by General National Pollutant Discharge Elimination System Permit for Storm Water Associated with Construction Activity (General Storm Water Permit), permit No. 3GC04614\*AG.

**Site Inspection**

It appears that appropriate corrective actions have been implemented to address all of the violations previously documented within Ohio EPA's notices of violation.

Once the site has been permanently stabilized, please remove all temporary sediment best management practices (i.e. silt fence, riser pipes, inlet protection, etc.) and install the permanent outlet structures for addressing the post-construction storm water management requirements.

**Notice of Termination**

Please be aware that all permittees must submit the notice of termination (NOT) form within 45 days of completing all permitted land disturbance activities. Enforcement actions may be taken if a permittee submits an NOT form without meeting one or more of the following conditions:

- a) Final stabilization (see definition in Part VII) has been achieved on all portions of the site for which the permittee is responsible (including, if applicable, returning agricultural land to its pre-construction agricultural use);
- b) Another operator(s) has assumed control over all areas of the site that have not been finally stabilized;
- c) For residential construction only, temporary stabilization has been completed and the lot, which includes a home, has been transferred to the homeowner. (Note: individual lots without housing which are sold by the developer must undergo final stabilization prior to termination of permit coverage.); or
- d) An exception has been granted under Part III.G.4.

For your convenience, NOT forms can be obtained from the following website:

<http://www.epa.ohio.gov/dsw/storm/stormform.aspx>

Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1118 or via e-mail [chris.moody@epa.ohio.gov](mailto:chris.moody@epa.ohio.gov).

Sincerely,



Chris Moody  
Environmental Specialist II  
Division of Surface Water

CM/cs

cc: Shawn Aiken, City of Conneaut  
Nick Sanford  
George Hess, Hess and Associates Engineering, Inc.

ec: Jason Hebert, Snavelly Excavating Company  
Nick Sanford, CT Consultants