



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

March 5, 2012

Village of Leesburg
7 East Street
Leesburg, OH 45135

**Re: Leesburg WWTP – 1PB00106*GD
Notice of Violation**

Dear Permittee:

A compliance review was conducted on your Discharge Monitoring Report (DMR) submitted on February 17, 2012. As detailed at the end of this letter, screening of your submitted DMR has identified compliance issues.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification, as to the reasons for the above referenced violations as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at Joshua.Jackson@epa.state.oh.us.

Respectfully,

Joshua Jackson
Environmental Specialist II
Division of Surface Water

JJ/tf

ec: philfloh2o@gmail.com



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Notice of Violation Report

Facility: Leesburg WWTP

Permit No.: 1PB00106*GD

Report Period: January 2012

Date Received: 2/17/2012

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Limit	1/1/2012	00530	Total Suspended Solids	Monthly Load	18	28.2034
001	Limit	1/15/2012	00530	Total Suspended Solids	Weekly Conc.	18	33.
001	Limit	1/15/2012	00530	Total Suspended Solids	Weekly Load	27	102.365
001	Limit	1/1/2012	01119	Copper, Total Recoverable	Monthly Conc.	22	25.
001	Limit	1/15/2012	80082	CBOD 5 day	Weekly Load	23	37.6664