



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: **Notice of Violation**  
Wood County  
Evergreen Plastics  
Stormwater Construction  
Permit No. 2GC02876\*AG

March 7, 2012

Mr. Mark Jeckering  
Janotta and Herner Inc.  
309 Monroe Street  
Monroeville, Ohio 44847

Dear Mr. Jeckering:

On February 9, 2012, I performed an inspection of the construction site for Evergreen Plastics located at 202 Water Tower Drive, Clyde, Sandusky County. The purpose of this visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity also known as the Construction General Permit (CGP). The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

As a result of the inspection, I have the following comments/observations:

1. At the time of the inspection, there was no active construction.
2. At the time of the inspection, the Storm Water Pollution Prevention Plan (SWP3) and inspection logs were not available for review. Please be aware that regular inspections of the sediment and erosion controls used at the site are to be made as per the CGP until the CGP is terminated.
3. Inlet protection has been provided on the storm catch basin inlet on the front of the property near Water Tower Drive.
4. An attempt to provide temporary stabilization was made with straw mulch. However, without a tackifier or other method of keeping the straw in place, many areas were bare. *This is a violation of Part III.G.2.b. of the CGP, which requires stabilization of any area that will remain undisturbed for 21 days or remain idle over the winter.*

Within 15 days of the date on this letter, please submit to this office **written notification** of the actions taken or proposed to prevent any future violations. Your response should include the dates, either actual or proposed, for the completion of the actions.

If you have any questions, you may contact me by e-mail at [patricia.tebbe@epa.state.oh.us](mailto:patricia.tebbe@epa.state.oh.us) or by phone at (419) 373-3016.

Sincerely,

Patricia A. Tebbe, P.E.  
Division of Surface Water

/jlm  
pc: James Moyer, P.E., Sandusky County Engineer  
Willis and Sons Inc.  
Sandusky SWCD  
Follow-up file  
ec: Inspection Tracking

Northwest District Office  
347 North Dunbridge Road  
Bowling Green, OH 43402-9398

419 | 352 8461  
419 | 352 8468 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)