



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Seneca County
Hanson Aggregates - Bloomville Quarry
NPDES Permit 2IJ00016

March 1, 2012

Mr. Chuck Kashian, Plant Manager
Hanson Aggregates - Bloomville Quarry
P.O. Box 128
Bloomville, Ohio 44818

Dear Mr. Kashian:

On January 6, 2012, an inspection was made of the waste water discharge at Hanson Aggregates Midwest - Bloomville Quarry. Mr. Jerry Beck, Lead Operator, was present and provided information regarding waste water treatment. Ground water, plant wash water, and storm water flow to the sedimentation pond prior to discharge.

We have received your NPDES permit renewal application. The permit renewal is currently being drafted and will be available shortly for your review.

A review of your monthly operating reports has also been conducted. A list of permit violations (January 2003 - May 2006) is enclosed on a separate sheet.

If there are any questions, please advise.

Yours truly,

Mary Beth Cohen
Division of Surface Water

/jlm

pc: Seneca County General Health District
Hanson Aggregates - Bloomville Quarry

ec: Inspection Tracking

Hanson Aggregates - Bloomville Quarry
NPDES Permit 21J00016

Limit Violations (outfall 001) June 2006 thru January 2012

Reporting Period	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2007	00530	Total Suspended Solids	30D Qty	93	98.1072	5/1/2007
December 2007	00530	Total Suspended Solids	30D Qty	93	114.458	12/1/2007
February 2008	00530	Total Suspended Solids	30D Qty	93	130.809	2/1/2008
May 2010	00530	Total Suspended Solids	30D Qty	93	130.809	5/1/2010

Frequency Violations (outfall 001) June 2006 thru January 2012

Reporting Period	Reporting Code	Parameter	Sample Frequency	Expected	Reported	Violation Date
February 2009	00530	Total Suspended Solids	1/Month	1	0	02/01/2009
February 2009	00400	pH	1/Month	1	0	02/01/2009
December 2010	00400	pH	1/Month	1	0	12/01/2010
December 2010	00530	Total Suspended Solids	1/Month	1	0	12/01/2010
February 2011	00530	Total Suspended Solids	1/Month	1	0	02/01/2011
February 2011	00400	pH	1/Month	1	0	02/01/2011