



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

March 16, 2012

RE: SUMMIT COUNTY
NORTON ACRES WWTP #13
COMPLIANCE EVALUATION INSPECTION
APPLICATION NO. OH0045853
OHIO EPA NO. 3PH00008

Mr. David E. Marquard
Summit County, Environmental Services
2525 State Road
Cuyahoga Falls, OH 44223

Dear Mr. Marquard:

On March 15, 2012, a Compliance Evaluation Inspection was conducted by this writer of Northeast District Office. Present during the inspection was Mr. Wiley Wyman of Summit County Department of Environmental Services.

The 121,000 gpd wastewater treatment plant consists of a comminutor, extended aeration, secondary clarifier, ultraviolet disinfection, post aeration, and an aerobic digester. During the recent inspection, the following observations were noted: The comminutor was operating properly. The aeration tanks had good air and roll, and the mixed liquor was the appropriate color with a slight amount of light brown foam. The skimmers in the clarifier were in operation. The clarifiers contained a slight amount of pinfloc. The aerated sludge holding tank was not being aerated.

Review of the Discharge Monitoring Reports from January 2010 through January 2012 revealed the following numeric effluent violations:

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2011	Total Suspended Solids	7D Qty	13.6	14.2647	3/1/2011
September 2010	Fecal Coliform	30D Conc	1000	1448.97	9/1/2010

Please be advised such instances of noncompliance are subject to enforcement pursuant to Ohio Revised Code (ORC) 6111.

In conclusion, all components of the treatment plant appeared to be operating properly, and maintenance of the plant was good. The effluent contained only a slight amount of visible solids. If you have any questions, please contact this office at (330) 963-1151.

Sincerely,

Jennifer S. Bennage
Environmental Engineer
Division of Surface Water

JSB/cs

cc: Robert Hollis, Summit County D.O.E.S.