



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

March 19, 2012

Victoria Bonner
Rennob / ABL Group
5380 Havenhill Drive
Columbus, OH 43235

Re: Cobbleton Development/ Franklin County

Dear Ms. Bonner:

This letter is written in follow-up to a construction storm water inspection that I conducted on March 15, 2012, at the Cobbleton Development located near the intersection of Ebright Road and Winchester Pike. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls:

There was no active construction during my inspection. The site was stabilized and no erosion appeared to be leaving the site. If construction does start again, please be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Stormwater Section
Division of Surface Water
Central District Office

ec: Gregory L. Sanders, DSW/CDO

GS/nsm Cobbleton Development, March 15, 2012