



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

March 5, 2012

Mark Demarest
Maronda Homes Inc
3811 Twin Creeks Drive
Columbus, OH 43204

Re: Hunter's Glen / Franklin County

Dear Mr. Demarest:

This letter is written regarding the storm water inspection that I conducted on February 28, 2012, at the Hunter's Glen construction site along Bowen Road in Franklin County. **It appears construction has not started at this site.** I understand that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

ec: Gregory Sanders, DSW/CDO

GS/nm Hunters Glen, February 28, 2012