



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Naily, Director

March 5, 2012

Todd Valentine
L. W. Associates, Inc.
184 West Main Street
Ashville, OH 43103

Re: Ashville Commerce Center / Pickaway County

Dear Mr. Valentine:

This letter is written regarding the storm water inspection that I conducted on February 29, 2012, at the Ashville Commerce Center, located at on State Route 752 in Pickaway County. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted at the site:

Sediment and Erosion Controls:

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

ec: Greg Sanders, DSW/CDO

GS/nsm Ashville Commerce Center, February 29, 2012