



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: **Notice of Violation**
Henry County
Campbell Soup Solar
Construction
Stormwater

March 23, 2012

Mr. Nathan Johnson
Vaughn Industries, LLC
1201 East Findlay Street
Carey, Ohio 43316

Dear Mr. Johnson:

On February 28, 2012, I was in the area of the Campbell Soup Solar site at P152 CO 12, Napoleon, Henry County. While the gate was locked to the site, I was able to do a partial inspection of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID #2GC02924*AG. This inspection was made under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

As a result of the inspection, I have the following comments/observations:

1. At the time of the inspection, the solar panels were installed.
2. At the time of the inspection, the Storm Water Pollution Prevention Plan (SWP3) and inspection logs were not available for review.
3. There was some cardboard litter in the parking area at the south end of the site.
4. The site has not been stabilized and erosion patterns are forming. *This is a violation of Part III.G.2.b.i. of the CGP, which requires that disturbed areas must be stabilized within seven days of reaching final grade.*
5. While most of the silt fence was standing, there are several areas around the site where the silt fence is down. *This is a violation of Part. V.N of the CGP.*

Mr. Nathan Johnson
March 23, 2012
Page Two

Within 15 days of the date on this letter, please submit to this office **written notification** of the actions taken or proposed to prevent any future violations. Your response should include the dates, either actual or proposed, for the completion of the actions. Please also include the portion of the SWP3 that gives the description and rationale for the selection of the post-construction controls of this site. This will also include the detail drawings and maintenance plans of the post-construction controls.

If you have any questions, please contact me by phone at (419) 373-3016 or by e-mail at patricia.tebbe@epa.state.oh.us.

Sincerely,

A handwritten signature in blue ink that reads "Patricia A. Tebbe". The signature is written in a cursive style with a large initial "P".

Patricia A. Tebbe, P.E.
Division of Surface Water

/jlm

pc: Timothy J. Schumm, P.E., P.S., County Engineer
Henry County SWCD

ec: Inspection Tracking