



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Richland County  
Brown Derby Roadhouse  
NPDES Permit

March 14, 2012

Mr. Bill Tsavaris, General Manager  
Brown Derby Roadhouse  
3985 Park Avenue West  
P.O. Box 223  
Ontario, Ohio 44862

Dear Mr. Tsavaris:

On February 23, 2012, an inspection was made of the waste water treatment facilities serving the Brown Derby Roadhouse located at 3985 Park Avenue West, Ontario, Richland County. At the time of the inspection, no major concerns were noted. A clear final effluent was being discharged to the receiving stream.

The level in the first two aeration tanks was only a few inches from within the top of the tanks. The other tank levels were normal. The transfer pipes between the tanks should be checked to make sure they are not partially blocked, which may cause this condition.

A review of your discharge monitoring reports (DMR) for the period of August 2011 through January 2012 revealed no violations of the limits in your NPDES permit.

A review of the operator's log revealed that the daily checks for odor, color, turbidity, and flow rate are still not being recorded. The need to make these daily checks was noted in our last inspection letter dated August 23, 2011. It is also required that the previous three months' of the log be present for inspection. No records were available since July 2011. The log indicated that a representative from McGhee's TWSI is on site once/week. It did not appear any other operator is visiting the treatment plant. Your NPDES permit requires that at least two visits per week for a total of one hour are made by the operator if record. All visits need to be recorded in the onsite log. All of these issues represent **violations** of the conditions of your NPDES permit and need to be corrected immediately.

Please call me at 419-373-3070 if you have any questions.

Sincerely,

Walter Ariss, P.E.  
Environmental Specialist II  
Division of Surface Water

/jlm

Enclosure

pc: Angelo Klousadis, City of Mansfield  
Lonnie McGhee, McGhee's Technical Water Services Inc.

ec: Inspection Tracking

OHIO ENVIRONMENTAL PROTECTION AGENCY

OPERATION AND MAINTENANCE INSPECTION  
 WWTP'S LESS THAN 25,000 GPD

NPDES Permit No. 2P1200049

Facility Name Brown Verby Roadhouse Expiration Date 4/30/2015

Facility Address 3785 Park Ave Date 2/23/12 Time 2:30 am/pm

City Ontario County Richland Township \_\_\_\_\_

Name and Address of Owner Bill Tsavari's

Person Contacted \_\_\_\_\_ Owner Phone \_\_\_\_\_

Flow: Design 5,000 GPD Present 1000-6000 GPD (metered - estimated)

Trib. Pop. \_\_\_\_\_ (actual - estimated) Weather at time of inspection: Temp 38° sun

OEPA Personnel Walter Ariss District NWDO

1. Plant Effluent - Mark Severity No.

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None	<input checked="" type="checkbox"/>	Clear	<input checked="" type="checkbox"/>	None	<input checked="" type="checkbox"/>	Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

2. Effect of effluent on Receiving Stream Name: Unroad Hill Clear Fork Holston

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None	<input checked="" type="checkbox"/>	Clear	<input checked="" type="checkbox"/>	None	<input checked="" type="checkbox"/>	Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

3. a. Plant has \_\_\_\_\_ excellent  good \_\_\_\_\_ fair \_\_\_\_\_ poor operation  
 b. Plant has \_\_\_\_\_ excellent  good \_\_\_\_\_ fair \_\_\_\_\_ poor maintenance  
 c. Sand filters have \_\_\_\_\_ excellent \_\_\_\_\_ good \_\_\_\_\_ fair \_\_\_\_\_ poor maintenance  
none

d. Not operating at expected efficiency due to:

- (1) \_\_\_\_\_ hydraulic overload  
 (2) \_\_\_\_\_ organic/ solids overload  
 (3) \_\_\_\_\_ personnel inefficiency  
 (4) \_\_\_\_\_ equipment failure  
 (5) \_\_\_\_\_ wastes  
 (6) \_\_\_\_\_

Disinfection: (Required May 1 thru Oct.31.)

IN	OUT	
_____	<input checked="" type="checkbox"/>	Chlorination Tablets
_____	<input checked="" type="checkbox"/>	Dechlorination Tablets
_____	_____	U.V.

Yes No

4.  Compliance with NPDES Permit

Periodic Violations Y N Parameters: \_\_\_\_\_  
 Chronic Violations \_\_\_\_\_ X \_\_\_\_\_

5.  Adequate plant safety

6.  Operation and Maintenance Service Name McGhee's

Frequency of Visits 1/week

Facility Name: Brown Derby Roadhouse

Process	# Units	Unit	If Needed - Description and Comments
Preliminary	X	Trash Trap	Pumping Frequency: ?
		Grease Trap	Pumping Frequency: ?
		Bar Screen	
		Comminutor	
		Flow Equalization	
Aeration Equipment	X	Plant Timer <u>Y</u> <del>X</del> N	Cycle Time: <u>one hour on</u>
		Motor/ Blower Unit <u>running</u>	<u>other is a backup</u>
Secondary Treatment	X	Aeration Tank <u>check transfer pipes - level in</u> <u>First tanks very high</u>	Color: <u>good color + roll</u> Adequate Aeration: <u>Y</u> <del>X</del> N <u>    </u>
Final Settling	X	Clarifier	<u>good clarity</u>
	X	Sludge Return	In <u>X</u> Out <u>    </u>
	X	Surface Skimmer	In <u>X</u> Out <u>    </u>
		Fixed Media Clarifier	
<del>Tertiary Treatment</del> <u>none</u>		Surface Sand Filter	
		Polishing Pond	
		Other	
Disinfection	X	Chlorine Tube Feeder <u>out</u>	<u>-check area around outside</u>
	X	Dechlorination Tube Feeder <u>out</u>	<u>of tank - ground is eroding</u>
		Ultraviolet (UV)	<u>over discharge pipe</u>
Flow Metering		Elapsed Pump Time	
	X	Recorder (continuous total)	<u>on water well</u>
<del>Pumps</del> <u>none</u>		Raw Wastewater (type)	
		Sand Filter Effluent Dosing	
<del>Sludge Handling</del> <u>none</u>		Aerated Storage Tank	
		Sludge Drying Bed	
Sludge Disposal	X	Municipal POTW	
		Landfill	
		Land Application	
Advanced Treatment	X	Post Aeration	<u>on</u>
		Spray Irrigation	
		Other	