



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

March 27, 2012

Re: Scioto County
ODNR Shawnee SP Lodge
Self-Monitoring Report Violations
Ohio EPA Permit 0PP00029
NPDES Permit OH0037885
Correspondence (PWW)

Mr. Martin McAllister, Park Manager
ODNR Shawnee State Park
4404 State Route 125
Portsmouth, Ohio 45663-9003

Dear Mr. McAllister:

We have received your self-monitoring reports covering the months of July through December 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
August 2011:						
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	8/4/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	8/5/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	8/9/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	8/10/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.09	8/11/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.25	8/12/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	8/15/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.11	8/16/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	8/17/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	8/19/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.13	8/23/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.09	8/24/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.09	8/25/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.26	8/29/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.08	8/30/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	8/31/2011
September 2011:						
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	9/1/2011

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	0.019	.06	9/2/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.07	9/7/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.06	9/8/2011
October 2011:						
001	31616	Fecal Coliform	1D Conc	2000	7400.	10/20/2011

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets and U.S. EPA's Facility Pollution Prevention Guide, (EPA/600/R-92/088), you may contact the Ohio EPA Pollution Prevention Section at (614) 644-3469 or me for additional information.

If there are any questions, please contact me at (740) 380-5227.

Sincerely,



Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh