



**Environmental  
Protection Agency**

**John R. Kasich, Governor**

**Mary Taylor, Lt. Governor**

**Scott J. Nally, Director**

April 9, 2012

RE: PRESSLER MEATS  
COMPLIANCE INSPECTION  
PERMIT NO. 3IH00046  
SUMMIT COUNTY

Mr. Roger Pressler  
Pressler Home Dressed Meats  
2553 Pressler Road  
Akron, Ohio 44312

Dear Mr. Pressler:

On April 6, 2012, this writer conducted a compliance evaluation inspection of your facility. On this day, the treatment plant appeared to be in good operation. The aeration chamber had a typical reddish brown color and was being properly aerated. The surface of the clarifier was clear, as was the weir trough. A temporary cover for the clarifier was observed made out of wood and a tarp. This is a good idea for the winter and also limits the production of algae. The sand filter beds were clean but were not level as the northern ends were noticeably higher resulting in the flow ponding on only half the filter. The filter beds should be raked level to dose the entire bed. A lot of sand has been removed from the bed. Care should be taken to maintain a depth of sand to adequately filter solids. Approximately one to two cubic yards of used filter sand has been piled next to the surface sand filters. This should be properly disposed. The effluent was clear and no visual problems were noted. Outfall 002 containing non-contact cooling water was also flowing clear.

Below you will find a summary of your NPDES permit compliance history for the time period of January 1, 2010 thru February 2012:


**Numeric Violations**

Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	Chlorine, Total Residu	1D Conc	0.038	.1	5/3/2010
001	Chlorine, Total Residu	1D Conc	0.038	.15	7/5/2010
001	Biochemical Oxygen Dem	30D Conc	10	12.	3/1/2010
001	Fecal Coliform	1D Conc	400	480.	9/13/2010
001	Chlorine, Total Residu	1D Conc	0.038	.2	6/7/2010
001	Fecal Coliform	1D Conc	400	2900.	7/4/2011
001	Biochemical Oxygen Dem	1D Conc	15	37.2	7/4/2011
001	Biochemical Oxygen Dem	30D Conc	10	37.2	7/1/2011
001	Biochemical Oxygen Dem	1D Qty	0.19	1.40802	7/4/2011
001	Biochemical Oxygen Dem	30D Qty	0.13	1.40802	7/1/2011
001	Nitrogen, Ammonia (NH3	1D Conc	3	6.33	6/6/2011
001	Nitrogen, Ammonia (NH3	30D Conc	2	6.33	6/1/2011
001	Nitrogen, Ammonia (NH3	1D Qty	0.04	.04792	6/6/2011
001	Nitrogen, Ammonia (NH3	30D Qty	0.03	.04792	6/1/2011
001	pH	1D Conc	9.0	9.85	11/7/2011

PRESSLER MEATS  
APRIL 9, 2012  
PAGE 2 OF 3

If you should have any questions concerning this letter, feel free to call this writer at  
(330) 963-1136.

Sincerely,



Philip P. Rhodes, P.E.  
Environmental Specialist II  
Division of Surface Water

PPR/cs

File: Industrial Permit\Compliance

Attachments: Pictures

