



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

April 11, 2012

RE: PLEASANT VIEW NORTH
451 VALLEY ROAD
BUTLER TWP.
COLUMBIANA COUNTY

Mr. Tim Chesney
Jilltin Management Group, LLC
888 Boardman-Canfield Rd., St A
Boardman, OH 44512

Dear Mr. Chesney:

On February 22, 2012, this writer conducted an inspection of the wastewater treatment plant for the Pleasant View North Retirement & Rehabilitation Center. The facility was represented by Mrs. Liz Shutler and Mr Edward Arkwright. The intent of the inspection was to evaluate operations and maintenance of the system. This facility is currently considered to be in significant noncompliance.

The following are findings from the inspection:

1. The facilities consist of a trash trap, followed by a flow equalization tank, 17,500-gpd extended aeration treatment plant, dosing chamber, surface sand filter, and chlorination/dechlorination facilities. The solids handling facilities include an aerated sludge holding tank and sludge drying beds. At the time of the inspection, the trash trap appeared satisfactory. The aeration tank had a good brown color and had a good role across the tank. The settling tank appeared satisfactory and the effluent was relatively clear.
2. The surface sand filters were operating satisfactory. Final effluent leaving the treatment plant was free of solids.
3. The electronic data monitoring reports were evaluated from February 2008 through January 2012. There were only four violations during that time period and none since October 2010. The plant appears to be receiving adequate operation and maintenance.

Your current permit will be expiring this year and the draft permit will be available for your review shortly. The Renewal application must be submitted to this office 180 days prior to expiration. The application must be signed by the owner.

You may contact this office at (330) 963-1193 to discuss any questions you may have.

Respectfully,

Joseph E. Trocchio, P.E.
Environmental Engineer
Division of Surface Water

JET/cs

cc: Liz Shutler, Columbiana County Health Dept.

File: Semipublic/Columbiana County/Butler Township/Pleasant View North