



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

April 26, 2012

Mayor & Council
Village of Higginsport
P.O. Box 121
Higginsport, OH 45131

**RE: Higginsport WWTP – 1PA00028*CD
Notice of Violation**

Dear Permittee:

A compliance review was conducted on your Discharge Monitoring Report (DMR) submitted on April 18, 2012. As detailed at the end of this letter, screening of your submitted DMR has identified compliance issues.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at Joshua.Jackson@epa.state.oh.us.

Respectfully,

Joshua Jackson
Environmental Specialist II
Division of Surface Water

JJ/ff

ec: Higginsport@Frontier.com



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**

Notice of Violation Report

Facility: Higginsport WWTP

Permit No.: 1PA00028*CD

Report Period: March 2012

Date Received: 4/18/2012

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Limit	3/1/2012	00610	Nitrogen, Ammonia (NH3)	Monthly Conc.	3.0	4.82
001	Limit	3/15/2012	00610	Nitrogen, Ammonia (NH3)	Weekly Conc.	4.5	9.54