



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

April 25, 2012

Don Evans  
Daifuku America Corp.  
6700 Tussing Road  
Reynoldsburg, OH 43068

**Re: Daifuku America Corp / Franklin County  
Construction Storm Water Permit 4GC03694\*AG**

Dear Mr. Evans:

This letter is written in follow-up to a construction storm water inspection that I conducted on April 17, 2012, at Daifuku America Corp, located at 6700 Tussing Road, Reynoldsburg, Ohio. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- Please be aware that the General Permit states that all barren areas including soil stockpiles which remain idle in excess of 21 days must be protected from erosion within 7 days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within 7 days. Most of the barren areas appeared to be at or near final grade.
- The general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
- You should receive approval for discharging any dewatering activities to the City of Columbus storm or sanitary sewers. Also, any discharge to the storm sewer should be discharged to a filter bag.
- Please maintain your concrete wash-out pit.

Don Evans  
Daifuku America Corp.  
Page 2 of 2

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851 or email at [greg.sanders@epa.state.oh.us](mailto:greg.sanders@epa.state.oh.us).

Sincerely,

A handwritten signature in black ink, appearing to read 'G.L.S.', written in a cursive style.

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

c: Norm Black, City of Columbus

ec: Greg Sanders, DSW/CDO

GS/nsm Daifuku America Corp, April 17, 2012