

Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

April 25, 2012

Bambi Baughn
CAC of Fayette County
1400 US Route 22
Washington Court House, OH 43160

**Re: Kearney Court, Pickaway County
Construction Storm Water Permit 4GC03444*AG**

Dear Ms. Baughn:

This letter is written in follow-up to a construction storm water inspection that I conducted on April 19, 2012, at Kearney Court, located along Beaumont Court, in New Holland, Ohio. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Construction appears to be completed. All areas appeared to be at final grade. I was told by the on-site person that barren areas would be stabilized the next day. Please be aware that the General Permit states that all barren areas at final grade must be stabilized within 7 days.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851 or email at greg.sanders@epa.state.oh.us.

Sincerely,



Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

ec: Greg Sanders, DSW/CDO

GS/nsm Kearney Court, April 19, 2012