

Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

April 26, 2012

Loren Hart
Ohio Department of Natural Resources
2045 Morse Road BLDG E-3
Columbus, Ohio 43229

Re: **Storm Water Inspection at Galena Launch Ramp, April 11, 2012**
Permit 4GC03670*AG

Dear Ms. Hart:

This letter is written regarding the storm water inspection I at Galena Launch Ramp in Franklin County on April 11, 2012. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted:


1. The perimeter silt fence is installed and appears to be functioning as intended.
2. All barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activity.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Galena Launch Ramp 4-11-2012

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov