



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

April 24, 2012

Jeremiah Johnson  
Beaver Excavating Company  
2000 Beaver Place Avenue  
Canton, OH 44706

**Re: Construction Storm Water Inspection at City of Columbus Upland Reservoir – Site #2 /  
Delaware County  
Permit Number: 4GC03524 \*AG**

Dear Mr. Johnson:

This letter is written regarding a storm water inspection I conducted at City of Columbus Upland Reservoir – Site #2 located at 10065 Taway Road Radnor, Ohio on April 5, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following in association with construction activities at this site:

**Sediment and Erosion Control:**

- During our inspection our team noted vast areas of disturbance. Please continue to implement positive drainage to sediment pond number one to minimize sediment discharges from the site.
- Currently, it appears the dewatering activities are handled correctly. Please continue with your daily dewatering log
- I evaluated the discharge points from the site which appeared clear.
- Please state in your response when all the outer berm construction will be completed seeded and mulched.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO