



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

April 24, 2012

Ron Strussion  
Reynoldsburg Public Schools  
7244 East Main Street  
Reynoldsburg, OH 43068

**Re: Construction Storm Water Inspection at Reynoldsburg High School  
Franklin County  
Permit Number: 4GC03547\*AG**

Dear Mr. Strussion:

This letter is written regarding a storm water inspection I conducted at Reynoldsburg High School located at 6699 East Livingston Avenue Reynoldsburg Ohio, on March 27, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination will be required provided the post construction requirements are met. Please address the following:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:  
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at:  
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

Ron Strussion  
Reynoldsburg Public Schools  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,



Henry Kalipolous  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/ism Reynoldsburg High School March 27, 2012