



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

April 24, 2012

David Dryden
Mount Carmel, St. Ann's Hospital
6150 East Broad Street
Columbus, Ohio 43213

Re: **Construction Storm Water Inspection of Permit 4GC036006*AG**
Location: **Cleveland Avenue, Franklin County**

Dear Mr. Dryden:

This letter is written regarding the storm water inspection I conducted of the recent construction activities at St. Ann's Hospital located on Cleveland Avenue in Franklin County on March 27, 2012. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

- The perimeter controls, specifically around the newest phase of construction required maintenance.
- I would strongly suggest the modification of the existing detention basin for purposes of sediment control.
- The large stock pile on the southeast part of the project, surrounded by silt fence must be protected from erosion.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

David Dryden
Mount Carmel, St. Ann's Hospital
Page -2-

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office