



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

May 1, 2012

Mr. Billy Slaven
City of Hamilton
2451 River Road
Hamilton, Ohio 45011

RE: Butler County, Hamilton WWTP, NPDES Permit Violations

Dear Mr. Slaven:

We have reviewed your Discharge Monitoring Reports covering the months of January through March 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0025445; OEPA Permit # 1PE00002*MD). The specific instance of noncompliance is as follows:

Effluent Violations for January through March 2012

Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
January 2012	TSS	Monthly	mg/l	30	37
January 2012	TSS	Weekly	mg/l	45	66

Please be advised that failure to comply with the effluent of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reason for the above violation and the action being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

Ned Sarle
Environmental Specialist
Division of Surface Water
Permit Section

NS/tf