



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

May 4, 2012

Re: Tuscarawas County
Greer Steel Company
Notice of Violation
OID00003, OH0005606
Correspondence (IWW)

Mr. Todd Daenzer, Operations Management
Greer Steel Company
624 Boulevard Street
Dover, Ohio 44622

Dear Mr. Daenzer:

We have received your self-monitoring reports covering the months of January through March 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
006	61942	pH, Minimum	1/29/2012	1D Conc	6.5	6.13
006	61941	pH, Maximum	2/22/2012	1D Conc	9.0	10.45

* 1D Conc is equal to the daily maximum concentration limit.

Non-Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type	Limit	Reported Value
006	61941	pH, Maximum	1/17/2012			AD
006	61942	pH, Minimum	1/17/2012			AD
006	01051	Lead, Total (Pb)	2/23/2012			AD
006	00550	Oil and Grease, Total	2/23/2012			AD
006	00530	Total Suspended Solids	2/23/2012			AD
006	01092	Zinc, Total (Zn)	2/23/2012			AD
006	01119	Copper, Total Recoverable	3/1/2012			AD
006	01051	Lead, Total (Pb)	3/1/2012			AD
006	00550	Oil and Grease, Total	3/1/2012			AD
006	00530	Total Suspended Solids	3/1/2012			AD
006	01092	Zinc, Total (Zn)	3/1/2012			AD

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,



Tim Fulks
District Representative
Division of Surface Water

TF/dh