



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

May 4, 2012

**Re:** Tuscarawas County  
Tolloti Plastic Pipe, Inc.  
Notice of Violation  
0IQ00025, OH0099767  
Correspondence (IWW)

Mr. Ted Tolloti  
Tolloti Plastic Pipe, Inc.  
P.O. Box 508  
New Philadelphia, Ohio 44663-0508

Dear Mr. Tolloti:

We have received your self-monitoring reports covering the months of January through March 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

**Numeric Violations:**

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	00310	Biochemical Oxygen Dem	1/11/2012	1D Conc	26	33.
001	00530	Total Suspended Solids	1/11/2012	1D Conc	19	27.

\* 1D Conc is equal to the daily maximum concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

Tim Fulks  
District Representative  
Division of Surface Water

TF/dh