Ohio Environmental Protection Agency
John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

May 4, 2012

Re: Guernsey County
Byesville Water Treatment Plant
Notice of Violation
0IY00100; OH0128112
Correspondence (IWW)

Mayor and Council
Village of Byesville
221 East Main Street
P.O. Box 8
Byesville, Ohio 43723

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of January through March 2012 for the Byesville water treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type *	Limit	Reported Value
001	50060	Chlorine, Total Residual	1/2/2012	1D Conc	0.019	.07
001	50060	Chlorine, Total Residual	1/4/2012	1D Conc	0.019	.07
001	50060	Chlorine, Total Residual	1/5/2012	1D Conc	0.019	.11
001	50060	Chlorine, Total Residual	1/8/2012	1D Conc	0.019	.1
001	50060	Chlorine, Total Residual	1/11/2012	1D Conc	0.019	.07
001	50060	Chlorine, Total Residual	1/12/2012	1D Conc	0.019	.07
001	50060	Chlorine, Total Residual	1/15/2012	1D Conc	0.019	.11
001	50060	Chlorine, Total Residual	1/25/2012	1D Conc	0.019	.08
001	50060	Chlorine, Total Residual	1/26/2012	1D Conc	0.019	.06
001	50060	Chlorine, Total Residual	2/5/2012	1D Conc	0.019	.1
001	50060	Chlorine, Total Residual	2/8/2012	1D Conc	0.019	.1
001	50060	Chlorine, Total Residual	2/10/2012	1D Conc	0.019	.1
001	50060	Chlorine, Total Residual	2/15/2012	1D Conc	0.019	.06
001	50060	Chlorine, Total Residual	2/19/2012	1D Conc	0.019	.06
001	50060	Chlorine, Total Residual	2/22/2012	1D Conc	0.019	.1
001	50060	Chlorine, Total Residual	2/23/2012	1D Conc	0.019	.1
001	50060	Chlorine, Total Residual	3/2/2012	1D Conc	0.019	.06
001	50060	Chlorine, Total Residual	3/9/2012	1D Conc	0.019	.08
001	50060	Chlorine, Total Residual	3/20/2012	1D Conc	0.019	.05
001	50060	Chlorine, Total Residual	3/21/2012	1D Conc	0.019	.05

* 1D Conc is equal to the Daily Maximum concentration limit.
30D Conc is equal to the monthly average concentration limit.

Southeast District Office
2195 Front Street
Logan, OH 43138-8637

740 | 385 8501
740 | 385 6490 (fax)
www.epa.ohio.gov

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

Tim Fulks
District Representative
Division of Surface Water

TF/dh

c: Thomas McVicker, Superintendent