



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

May 4, 2012

Re: Noble County
Caldwell WWTP
Notice of Violation
0PB00005; OH0127728
Correspondence (PWW/Major)

Mayor and Council
Village of Caldwell
Railroad Street
Caldwell, Ohio 43724

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of January through March 2012 for the Caldwell WWTP. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	00530	Total Suspended Solids	1/1/2012	30D Conc	14	16.5
001	00530	Total Suspended Solids	1/1/2012	30D Qty	42.4	51.7527
001	00530	Total Suspended Solids	1/1/2012	7D Conc	21	31.
001	00530	Total Suspended Solids	1/1/2012	7D Qty	63.6	71.5308

* 1D Conc is equal to the daily maximum concentration limit.
 1D Qty is equal to the daily maximum loading limit.
 7D Conc is equal to the weekly average concentration limit.
 7D Qty is equal to the weekly average loading limit.
 30D Conc is equal to the monthly average concentration limit.
 30D Qty is equal to the monthly average loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

A handwritten signature in cursive script, appearing to read "Tim Fulks".

Tim Fulks
District Representative
Division of Surface Water

TF/dh

c: Mr. Arthur Schockling, Superintendent, Village of Caldwell