



**Environmental Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

May 4, 2012

**Re:** Guernsey County  
ODOT Rest Area 5-30  
Notice of Violation  
OPP00058; OH0076929  
Correspondence (PWW)

Mr. Terry Gregg, Operator  
ODOT, District 5  
P.O. Box 306  
Jacksontown, Ohio 43030

Dear Mr. Gregg:

We have received your self-monitoring reports covering the months of January through March 2012 for the ODOT Rest Area facility number 5-30. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

**Numeric Violations:**

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	00610	Nitrogen, Ammonia	2/22/2012	7D Conc	6.0	29.6
001	00610	Nitrogen, Ammonia	2/8/2012	7D Conc	6.0	6.32
001	00610	Nitrogen, Ammonia	2/1/2012	30D Conc	4.0	14.44
001	00610	Nitrogen, Ammonia	2/1/2012	7D Conc	6.0	7.4
001	00610	Nitrogen, Ammonia	1/1/2012	30D Conc	4.0	5.8415
001	00610	Nitrogen, Ammonia	1/1/2012	7D Conc	6.0	11.4

\* 7D Conc is equal to the weekly average concentration limit.  
30D Conc is equal to the monthly average concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

A handwritten signature in cursive script, appearing to read "Tim Fulks".

Tim Fulks  
District Representative  
Division of Surface Water

TF/dh