



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

May 4, 2012

**Re:** Guernsey County  
Seneca Lake Campground  
Notice of Violation  
OPX00002; OH0059102  
Correspondence (PWW)

Mr. Boris Slogar, Chief Engineer  
Muskingum Watershed Conservancy District  
1319 3rd Street, N.W.  
P.O. Box 349  
New Philadelphia, Ohio 44663

Dear Mr. Slogar:

We have received your self-monitoring reports covering the months of January through March 2012 for the Seneca Lake Lagoon wastewater facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

**Numeric Violations:**

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	00665	Phosphorus, Total (P)	1/1/2012	30D Conc	1.0	1.04
001	00665	Phosphorus, Total (P)	2/1/2012	30D Conc	1.0	1.02
001	00665	Phosphorus, Total (P)	3/1/2012	30D Conc	1.0	1.18

\* 1D Conc is equal to the Daily Maximum concentration limit  
 1D Qty is equal to the daily maximum loading limit.  
 7D Conc is equal to the weekly average concentration limit.  
 7D Qty is equal to the weekly average loading limit.  
 30D Conc is equal to the monthly average concentration limit.  
 30D Qty is equal to the monthly average loading limit

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

A handwritten signature in blue ink, appearing to read "Tim Fulks".

Tim Fulks  
District Representative  
Division of Surface Water

TF/dh

c: Gary Taylor, Operator, MWCD