



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

May 10, 2012

RE: HOLMES COUNTY
CITY OF MILLERSBURG
TOM BIRD ENTERPRISES
NPDES PERMIT NO. OHC000002
OHIO EPA PERMIT NO. 3GC02087*AG
CONSTRUCTION STORM WATER INSPECTION

Tom Bird
Tom Bird Enterprises
P.O. Box 127
Millersburg, OH 44654

Dear Mr. Conn:

On April 11, 2012, Ohio EPA conducted an inspection of New Pointe Community Church - Millersburg, located 1690 South Washington Street, City of Millersburg, Holmes County (site). The site was represented by Abe Yoder, Project Manager, of Ivan Weaver Construction. Ohio EPA records indicate that the site is covered by General National Pollutant Discharge Elimination System Permit for Storm Water Associated with Construction Activity (General Storm Water Permit), permit No. 3GC02087*AG. The inspection documented the following violations:

Storm Water Inspection

- Offsite tracking of sediment was occurring into South Washington Street due to the failure to have a properly installed construction entrance. A properly designed construction entrance must be installed.
- No sediment controls (i.e. silt fence and sediment settling pond outlet structure) have been installed along the western and southern property boundaries to prevent sediment-laden runoff from entering "waters of the state." Silt fence and the riser pipe depicted on the site's storm water pollution prevention plan must be installed.
- All idle areas must be stabilized once construction activities are completed.

Via four e-mails sent to Ohio EPA on April 12, 2012 by Lindsey Taylor of Bird Enterprises, Inc., the above three violations have been addressed by appropriate corrective actions. Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1118 or via e-mail at chris.moody@epa.ohio.gov.

Sincerely,

Chris Moody
Environmental Specialist II
Division of Surface Water

CM/cs