



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Lucas County
Filling Property for Future Development
Construction
Storm Water

May 16, 2012

Mr. Willard Sturt
Toledo Paving
3404 Silica Road
Sylvania, Ohio 44847

Dear Mr. Sturt:

On May 8, 2012, I inspected the Filling Property for Future Development project on the northeast corner of Centennial and Silica Roads, Sylvania Township. The purpose of my visit was to evaluate compliance of the site with your National Pollutant Discharge Elimination System (NPDES) permit for storm water associated with construction activity (Construction General Permit or CGP), Facility ID No. 2GC02422. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. According to our records, no other permittees have been granted CGP coverage for this site.

At the time of inspection, the site was inactive and no earth moving equipment was observed. The site has been seeded and appeared to have a good cover of grass. Due to the absence of personnel or a construction trailer, the Storm Water Pollution Prevention Plan (SWP3) and inspection logs were not available for review. No further action is required at this time under Ohio EPA's Construction General Permit. Please be sure to use appropriate sediment and erosion controls, such as silt fence and temporary stabilization methods (mulching, mulch with seeding, etc.) when the project resumes. If there are any questions, I may be reached at (419) 373-3009.

Sincerely,

Lynette M. Hablitzel, P.E.
Division of Surface Water
Storm Water Program

/jlm

ec: Jeff Grabarkiewicz, Lucas County SWCD
Brian Miller, P.E., Lucas County Engineer's Office
Inspection Tracking
pc: File