



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

May 17, 2012

Paul Frair  
Brexton  
815 Grandview Avenue  
Suite 300  
Columbus, OH 43215-1254

Re: **Potters House Church of God, Franklin County**

Dear Mr. Frair:

This letter is written regarding the storm water inspection that I conducted on May 15, 2012, at the Potters House Church of God, located at 3220 Lowell Drive, in Columbus, Ohio. I understand that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed.

1. I noted that construction appears to be completed at the site. Most areas were stabilized, however, there were a few small areas that may need to be re-seeded. Please see attached pictures.
2. The General Permit mandates specific water quality treatment for storm water following the completion of construction (see attachment). Please be able to demonstrate your post construction requirements per the General Permit will be met. Please submit to my attention the water quality calculations demonstrating compliance. This information can be sent to my attention via a response letter, or to my email at [greg.sanders@epa.state.oh.us](mailto:greg.sanders@epa.state.oh.us).
3. If you have not already done so, a Notice of Termination will be required providing that the post construction requirements have been met. Instructions and forms can be found at <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

Enclosure

c: Jerry Davis, Potters House Church of God

GS/nsm Potters House Church of God, May 15, 2012

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)

