

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

May 11, 2012

RE: SUMMIT COUNTY  
BOSTON HEIGHTS  
BUDGET INN  
5891 AKRON-CLEVELAND ROAD  
COMPLIANCE EVALUATION INSPECTION  
OHIO EPA NO. 3PR00085

**NOTICE OF VIOLATION**

**CERTIFIED MAIL**

Mr. Peter Patel, Owner  
Budget Inn  
5891 Akron-Cleveland Road  
Hudson, OH 44236

Dear Mr. Patel:

On May 7, 2012, a Compliance Evaluation Inspection was conducted at the wastewater treatment plant serving Budget Inn. The wastewater treatment system consists of a 500-gallon trash trap, 3500-gallon extended aeration plant, 1000-gallon dosing chamber, 272 square foot surface sand filter, and 345-gallon chlorination/dechlorination tank. The plant discharges to a tributary of Boston Run, which proceeds to the Cuyahoga River.

During the inspection, the plant was running, but the mixed liquor did not have the appropriate chocolate brown color, indicating that proper treatment may not be occurring. The clarifier was clean of solids, but the surface sand filters were close to overflowing with untreated sewage containing floating sludge and pinfloc. Please note that a discharge of raw sewage to waters of the state is a violation of Ohio Revised Code (ORC) 6111 and subject to enforcement action. Such a discharge is also a risk to public health and the environment.

Review of your facility's Discharge Monitoring Reports from May 2011 to May 2012 revealed the following numeric effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2011	001	Total Suspended Solids	30D Conc	12	15.	5/1/2011
May 2011	001	Nitrogen, Ammonia (NH3	30D Conc	1.5	31.	5/1/2011
May 2011	001	Nitrogen, Ammonia (NH3	7D Conc	2.3	26.	5/1/2011
May 2011	001	Fecal Coliform	30D Conc	1000	1602.49	5/1/2011
May 2011	001	Fecal Coliform	7D Conc	2000	8560.	5/1/2011
May 2011	001	CBOD 5 day	30D Conc	10	21.55	5/1/2011
May 2011	001	CBOD 5 day	7D Conc	15	35.8	5/1/2011
May 2011	001	Dissolved Oxygen	1D Conc	6.0	.02	5/5/2011
May 2011	001	Nitrogen, Ammonia (NH3	7D Conc	2.3	36.	5/15/2011
May 2011	001	Dissolved Oxygen	1D Conc	6.0	1.	5/19/2011


BUDGE INN  
MAY 11, 2012  
PAGE 2 OF 2

July 2011	001	Nitrogen, Ammonia (NH3	30D Conc	1.5	9.7	7/1/2011
July 2011	001	Nitrogen, Ammonia (NH3	30D Qty	0.02	.03671	7/1/2011
July 2011	001	Fecal Coliform	30D Conc	1000	4400.	7/1/2011
July 2011	001	CBOD 5 day	30D Conc	10	12.49	7/1/2011
July 2011	001	Nitrogen, Ammonia (NH3	7D Conc	2.3	9.7	7/22/2011
July 2011	001	Nitrogen, Ammonia (NH3	7D Qty	0.03	.03671	7/22/2011
July 2011	001	Fecal Coliform	7D Conc	2000	4400.	7/22/2011
January 2012	001	Nitrogen, Ammonia (NH3	30D Conc	4.0	13.2	1/1/2012
January 2012	001	CBOD 5 day	30D Conc	10	11.8	1/1/2012
January 2012	001	Nitrogen, Ammonia (NH3	7D Conc	6.0	13.2	1/22/2012
February 2012	001	Total Suspended Solids	30D Conc	12	17.	2/1/2012
February 2012	001	Nitrogen, Ammonia (NH3	30D Conc	4.0	13.6	2/1/2012
February 2012	001	CBOD 5 day	30D Conc	10	12.07	2/1/2012
February 2012	001	Nitrogen, Ammonia (NH3	7D Conc	6.0	13.6	2/22/2012
March 2012	001	Total Suspended Solids	30D Conc	12	23.	3/1/2012
March 2012	001	Nitrogen, Ammonia (NH3	30D Conc	4.0	13.5	3/1/2012
March 2012	001	CBOD 5 day	30D Conc	10	11.99	3/1/2012
March 2012	001	Total Suspended Solids	7D Conc	18	23.	3/15/2012
March 2012	001	Nitrogen, Ammonia (NH3	7D Conc	6.0	13.5	3/15/2012
March 2012	001	pH	1D Conc	6.5	5.8	3/15/2012

Please be advised such instances of significant non-compliance are also subject to enforcement pursuant to ORC 6111.

With the assistance from your treatment plant operator, please send an explanation for the above violations along with a plan of action to alleviate the violations. In addition, this office would like to meet your certified operator at the site to discuss operations and maintenance of the plant. If you have any questions, please contact this office at (330) 963-1151.

Sincerely,



Jennifer S. Bennage  
Environmental Engineer  
Division of Surface Water

JSB/cs

cc: Steve Howe, AKE  
Tom LaPlante, Summit County Health Dept.

7011 0470 0002 3496 2334

U.S. Postal Service™  
**CERTIFIED MAIL™ RECEIPT**  
*(Domestic Mail Only; No Insurance Coverage Provided)*

For delivery information visit our website at [www.usps.com](http://www.usps.com).

**OFFICIAL USE**

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
<b>Total Postage &amp; Fees</b>	<b>\$</b>

Postmark  
Here

*Sent To*

-----  
*Street, Apt. No.,  
or PO Box No.*  
-----  
*City, State, ZIP+4*



Ohio

Environmental Protection Agency

Northeast District Office  
2110 East Aurora Road  
Twinsburg, OH 44087-1924

CERTIFIED MAIL™



7011 0470 0002 3496 2334



*JEAN ANK*  
*Mr Peter AT 5891*

MR. PETER PATEL, OWNER  
BUDGET INN  
5891 AKRON-CLEVELAND ROAD  
HUDSON, OH 44236

ATTEMPTED, NOT KNOWN

RECEIVED

MAY 2 1 2012

ANK

OHIO EPA NEDO

4423632009 0018



PS Form 3811, February 2004  
Domestic Return Receipt  
102595-02-M-1540

2. Article Number  
*2011047000034962334*  
*See slip*

1. Article Addressed to:  
Mr. Peter Patel, Owner  
Budget Inn  
5891 Akron-Cleveland Road  
Hudson, OH 44236

3. Service Type  
 Certified Mail  
 Express Mail  
 Registered  
 Insured Mail  
 C.O.D.  
Return Receipt for Merchandise

4. Restricted Delivery? (Extra Fee)  
 Yes

D. Is delivery address different from item 1?  Yes  No  
If YES, enter delivery address below:

E. Received by (Printed Name) \_\_\_\_\_  
C. Date of Delivery \_\_\_\_\_

A. Signature \_\_\_\_\_  
 Agent  
 Addressee

COMPLETE THIS SECTION ON DELIVERY

SENDER: COMPLETE THIS SECTION

Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.  
Print your name and address on the reverse so that we can return the card to you.  
Attach this card to the back of the mailpiece, or on the front if space permits.

PLACE STICKER AT TOP OF ENVELOPE TO THE RIGHT OF THE RETURN ADDRESS. FOLD AT DOTTED LINE.

