



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

May 23, 2012

RE: STARK COUNTY
BETHLEHEM TOWNSHIP
LAKE SHERMAN MHP
NPDES NO. 3PV00035

Mr. Jeffrey Yorick, P.E.
UMH Properties, Inc.
1275 Forman Drive
Morgantown, WV 26508

Dear Mr. Yorick:

On May 10, 2012, this writer conducted a compliance evaluation inspection (CEI) of the wastewater treatment system serving the above referenced facility. Present during the inspection was Ron Miller, Wastewater Treatment Plant Operator, Lake Sherman MHP.

At the time of the inspection, the mixed liquor in the aeration tanks had a good brown color, indicative of a properly operating biological system. The steel final clarifier was producing an acceptable effluent. The concrete final clarifier was full of solids and the skimmer was above the water line. There was also excessive buildup of solids behind the scum baffle in the clarifier. The solids need to be removed and the skimmer adjusted. Additionally, the four sand filter beds were in poor condition. The beds were covered with solids and vegetation. The sand filter beds should be cleaned and raked as soon as possible.

A review of your Discharge Monitoring Reports (DMRs) covering the period January 2011 through April 2012 revealed the following effluent violations.

Permit No	Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.07	6/1/2011
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.07	6/2/2011
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.09	6/3/2011
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.08	6/6/2011
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.05	6/7/2011
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.06	6/8/2011
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.06	6/9/2011
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.05	6/10/2011
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.05	6/13/2011
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.09	6/16/2011
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.06	6/17/2011
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.05	6/21/2011
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.05	6/24/2011
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.09	6/27/2011
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.05	6/28/2011
3PV00035*ED	June 2011	001	Chlorine, Total Residu	1D Conc	0.019	.08	6/30/2011

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Sincerely

A handwritten signature in black ink, appearing to read 'Todd Surrena', with a long horizontal line extending to the right.

Todd Surrena
Engineering Geologist
Division of Surface Water

TS/cs

cc: Todd Ascani, Stark County Health Department

File: Semi-Public/Lake Sheran MHP