



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

April 25, 2012

Steve Studenmund  
Columbus & Franklin County Metro Park District  
1069 West Main Street  
Columbus, OH 43081

**Re: Walnut Woods Metro Park, Franklin County  
General Storm Water Permit #4GC03386\*AG**

Dear Mr. Studenmund:

This letter is written in follow-up to a construction storm water inspection that I conducted on April 18, 2012, at the Walnut Woods Metro Park located at 6716 Lithopolis Road, Groveport, Ohio. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

**Sediment and Erosion Controls:**

It appeared during the inspection that construction activity is nearly complete for this site and most all disturbed areas include a large stockpile have been permanently stabilized. However, there was an area that was receiving spoil from another site that needs to be stabilized. This area is located near the front entrance behind the park office building. Erosion controls should be installed around this area.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

ec: Greg Sanders, DSW/CDO

GS/nsm Walnut Woods Metro Park, April 18, 2012