



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

May 29, 2012

David G. Robertson, Wastewater Supt.  
Hebron WWTP  
934 W Main St.-PO Box 898  
Hebron, OH 43025

**Re: Hebron WWTP  
NPDES Permit 4PB00005/ OH0021539  
Reconnaissance Inspection  
Licking County**

Dear Mr. Robertson:

On March 13, 2012, a Reconnaissance Inspection was conducted at the Hebron WWTP. Present for the inspection were Keith Corwin and Tom Coleman of the Hebron WWTP, and Paul Vandermeer of the Ohio EPA, Central District Office, Division of Surface Water.

The purpose of the inspection was to evaluate compliance with the terms and conditions of your NPDES permit and to evaluate the operation and maintenance of the plant. The findings of the inspection are listed below:

- The WWTP appeared to be functioning satisfactorily and was well maintained. Minor violations of the NPDES permit in September and October of 2011 were addressed and the plant has been in full compliance since that time.
- Record keeping and operator logs were found to be in good order.
- Sludge handling beds seemed filled to capacity with geobags. Dewatered sludge in one geobag was in the process of being removed for disposal. Adequate sludge storage was still available in the sludge storage tank.

If you have any questions or comments concerning the enclosed inspection report, please contact me at (614) 728-3854 or e-mail at [paul.vandermeer@epa.ohio.gov](mailto:paul.vandermeer@epa.ohio.gov).

Sincerely,

Paul L. Vandermeer  
Environmental Specialist  
Compliance and Enforcement Unit  
Division of Surface Water  
Central District Office

ec: Paul L. Vandermeer

PLV/nsm Hebron

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)

## Compliance Data for Hebron WWTP between 3/1/2011 to 3/1/2012

### Summary

Permit Effluent Limit Violations: 5  
 Permit Effluent Code Violations: 0  
 Permit Effluent Frequency Violations: 0  
 Compliance Schedule Violations: 0

Limit Violations						
Reported Date	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
September 2011	001	Nitrogen, Ammonia (NH3)	30D Conc	1.0	1.21907	9/1/2011
September 2011	001	Mercury, Total (Low Le	30D Conc	12	21	9/1/2011
September 2011	001	Nitrogen, Ammonia (NH3)	7D Conc	1.5	1.64667	9/15/2011
October 2011	001	Total Suspended Solids	7D Conc	18	31.3333	10/15/2011
October 2011	001	Total Suspended Solids	7D Qty	102.2	163.993	10/15/2011

## Compliance Data for Hebron WWTP between 3/1/2011 to 3/1/2012

### Summary

Permit Effluent Limit Violations: 5  
 Permit Effluent Code Violations: 0  
 Permit Effluent Frequency Violations: 0  
 Compliance Schedule Violations: 0

Limit Violations						
Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation D
September 2011	001	Nitrogen, Ammonia (NH3	30D Conc	1.0	1.21907	9/1/2011
September 2011	001	Mercury, Total (Low Le	30D Conc	12	21.	9/1/2011
September 2011	001	Nitrogen, Ammonia (NH3	7D Conc	1.5	1.64667	9/15/2011
October 2011	001	Total Suspended Solids	7D Conc	18	31.3333	10/15/2011
October 2011	001	Total Suspended Solids	7D Qty	102.2	163.993	10/15/2011