



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

May 29, 2012

Michael Dunkle
Greenlawn Realty Company
555 Greenlawn Avenue
Columbus, OH 43223

Re: Enchanted Acres South, Franklin County

Dear Mr. Dunkle:

This letter is written regarding the storm water inspection that I conducted at Enchanted Acres South on May 24, 2012, located along Parsons Avenue, in the Village of Obetz, Ohio. There was active construction at the site. I understand that these construction activities are covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

- There was active construction at the site. There were no erosions controls. However, there was a small construction area in the middle of a large grassy field. No sediment was discharging off-site.
- Please be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. If the construction site becomes larger, please install erosion controls such as silt fence around the barren areas.
- Additional gravel was placed at the site near the haul road entrance. No mud was being tracked off-site.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,



Gregory L. Sanders
Storm Water Unit
Division of Surface Water
Central District Office

ec: Greg Sanders, DSW/CDO

GS/nsm Enchanted Acres South, May 24, 2012