



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

April 18, 2012

Melody George  
Berkshire Township  
201 North Galena Road  
Sunbury, Ohio 43074

**Re: Construction Storm Water Inspection of Berkshire Fill Site, Permit 4GC03657\*AG**

Dear Ms. George:

This letter is written regarding the storm water inspection I conducted of the Berkshire Township fill site located on State Route 37 in Delaware County on March 21, 2012. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment and Erosion Controls:**

1. Continue with seeding efforts to ensure an effective vegetative cover sufficient to control erosion, measures by a minimum density of 70 percent. The current cover is not adequate.
2. Based on my observations of the operations a sediment trap/pond is recommended for the fill slope.
3. Please ensure all appropriate permits are addressed for any crossing or fill of waters of the state such as a small stream or wetland.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Berkshire twp 3-21-2012