



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

April 24, 2012

Nathan Coey  
City of Pataskala  
621 West Broad, Suite 1-D  
Pataskala, Ohio 43062

**Re: Construction Storm Water Inspection of Oaks Sanitary Sewer  
Permit Number 4GC03782\*AG**

Dear Mr. Coey:

This letter is written in follow-up to a construction storm water inspection I conducted of construction activities associated with the Oaks Sanitary Sewer installation located along the west side of State Route 310, just north of State Route 16 on March 30, 2012. The following items were noted:

- The Notice of Intent application was received and processed.
- The area was recently regarded seeded and mulched.
- Please ensure a successful vegetative covered measured by a minimum density of 70 percent.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/insm City of Pataskala 3-30-2012

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)