



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

March 8, 2011

William Lemmon
Lemmon & Lemmon Inc
1201 South Main Street
North Canton, OH 44720

**Re: Construction Storm Water Inspection at Parkside Village / Delaware County
Permit Number 4GC02983*AG**

Dear Mr. Lemmon:

This letter is written in follow-up to a construction storm water inspection I conducted at Parkside Village in Westerville, Ohio on February 16, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. The following was noted:

Sediment and Erosion Control:

- The entire site has been recently protected from erosion with a mulch cover. Please establish the required vegetative cover measured by a minimum density of 70 percent for all affected areas prior to your submittal of the Notice of Termination.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Parkside Village 2-16-2012