



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

April 23, 2012

Tucker Bohm  
Damiler Group  
1533 Lake Shore Drive  
Columbus, Ohio 43204

**Re: Construction Storm Water Inspection of Permit 4GC03760\*AG**  
**Location: Near intersection of Africa and Maxtown in Delaware County.**

Dear Mr. Bohm:

This letter is written regarding the storm water inspection I conducted of the recent construction activities near the intersection of Maxtown Road and Africa Road on March 27, 2012. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment and Erosion Controls:**

- Area construction has recently commenced, as noted minor grading activities on the east side of the site. According to the General Permit, all sediment controls must be installed within seven days from initial grubbing activities.

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Damiler Group 3-27-2012