



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

May 31, 2012

NCDCBT LLC  
5695 Avery Road  
Dublin, Ohio 43016

**Re: Storm Water Inspection at Fill Site located at intersection of US Route 23 and Greif Parkway in Delaware County**

Dear Sir or Madame:

This letter is written in follow-up to a complaint investigation I conducted of the fill activities located at the intersection of US Route 23 and Greif Parkway in Delaware Ohio on **May 24, 2012**. This site (specifically located at N40.22178, W83.03460) is greater than one acre and is currently in violation for construction activities without a Construction Storm Water Permit issued by Ohio EPA.

I have received an application and Storm Water Plan from your consultant. The application is currently issued with a specific **permit number 4GCO00070**. I did not observe additional fill placement at the time of my inspection.

In accordance with 40 CFR 122.26, the following items require attention:

**Sediment and Erosion Controls:**

- Appropriate measures should be taken to ensure the area is properly protected from erosion. Given the time of year a crimped straw mulch cover is expected. **The straw mulch application or equivalent was not applied. The required time frame has passed.** Immediate measures are expected to avoid the potential of an enforcement action.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). **At this time, I am formally requesting a response to this letter within seven days for receipt (email preferred [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)).**

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/ns:m NCDCBT Fill Site 5-24-2012