Ohio | Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 6, 2012

Han Nguyen
Keystone Construction, Incorporated
2415 South High Street
Columbus, OH 43207

Re: Suburban Village / Pickaway County

Dear Mr. Nguyen:

This letter is written in follow-up to a construction storm water inspection that I conducted on May 30, 2012, at the Suburban Village located at the corner of Jefferson Street and Station Street. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Sediment and Erosion Controls:

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

ec: Greg Sanders, DSW/CDO

GS/nsm Suburban Village, May 30, 2012

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov