



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Lucas County
Sanitary Sewer Line No. 793A
Construction
Storm Water

June 6, 2012

Mr. Jim Shaw
Lucas County Sanitary Engineer
1111 South McCord Road
Holland, Ohio 43528

Dear Mr. Shaw:

On May 25, 2012, Lynette Hablitzel, Bernard Weik, and I inspected the area of Sanitary Sewer Line No. 793A, located on Monclova Road between Coder Road and Blackstone Drive, in Monclova Township. The purpose of our visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2CG03055*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. No one was present at the time to provide information on the project, and we show that there are no co-permittees.

At the time of the inspection, utility lines were marked but no earthwork was occurring and no construction equipment was present. On the Notice of Intent (NOI) permit application, the proposed start date of this project was April 1, 2012. When construction does commence, please remember the permit requirements for storm water management during construction and post construction, such as weekly self-inspections and the requirement to apply cover on bare soil in any areas that will sit idle for more than 21 days. Your sediment controls must be installed within seven days of grubbing and before any grading.

If you have any questions, please contact me at (419) 373-3025.

Sincerely,

Jessica Heitman
Division of Surface Water
Storm Water Program

/jlm

ec: Inspection Tracking