



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Lucas County
Perrysburg-Holland Road Bridge #1549
Over Swan Creek
Construction
Storm Water

June 6, 2012

Mr. Joel S. Palermo
Lucas County Engineer
One Government Center, Suite 870
Toledo, Ohio 43604-2258

Dear Mr. Palermo:

On May 25, 2012, Lynette Hablitzel, Bernard Weik, and I inspected the area of Perrysburg-Holland Road Bridge #1549 Over Swan Creek, Facility No. 2GC03099*AG. At the time of the inspection, no earthwork was occurring and no construction equipment was present. On the Notice of Intent (NOI) permit application, the proposed start date of this project is June 30, 2012. When construction does commence, please remember the permit requirements for storm water management during construction and post construction, such as weekly self-inspections and the requirement to apply cover on bare soil in any areas that will sit idle for more than 21 days. Your sediment controls must be installed within seven days of grubbing and before any grading.

Please send a written reply within 10 days of the date of this letter describing how the post construction storm water management requirements will be met for this project. Your reply should include the type(s) of practices you are implementing and the basis for their design.

If there are any questions, please contact me at (419) 373-3025.

Sincerely,

Jessica Heitman
Division of Surface Water
Storm Water Program

/jlm

ec: Inspection Tracking