



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

RE: **Notice of Violation**
Auglaize County
Wapakoneta WWTP
Ohio EPA Permit No. 2PD00019
NPDES Permit No. OH0027952

June 6, 2012

Mr. Robert Burns
Superintendent
Wapakoneta WWTP
P.O. Box 269
Wapakoneta, Ohio 45895

Dear Mr. Burns:

We are in receipt of your self-monitoring reports covering the months of January through March 2012 for the referenced facility. Our review indicates a violation of the conditions of your National Pollutant Discharge Elimination System (NPDES) permit. The specific instance of non-compliance is enclosed on a separate sheet.

Within 10 days of the date of this letter, please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit, may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur, and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's website at <http://epa.ohio.gov/ocapp> or by calling (614) 644 – 3469.

If there are any questions, please contact Mr. Justin Williams at (419) 373 – 3022.

Sincerely,

Thomas Poffenbarger, P.E.
Water Quality Engineer II/Unit Supervisor
Division of Surface Water

JAW/jlm
Enclosure
ec: Inspection Tracking

Get New Data

Violation for Wapakoneta WWTTP - January - March 2012

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PD00019*MD	March 2012	001	50092	Mercury, Total (Low Le	30D Conc	1.3	1.44	3/1/2012