



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**

May 10, 2012

SUMMIT COUNTY
SPRINGFIELD TOWNSHIP
FIREHOUSE GRILLE & PUB
COMPLIANCE EVALUATION INSPECTION
NPDES NO. 3PR00439

Mr. Tony Jaber
TJ Land Management
3560 Hubert Avenue
Mogadore, OH 44260

NOTICE OF VIOLATION LETTER

CERTIFIED MAIL

Dear Mr. Jaber:

On May 7, 2012, a Compliance Evaluation Inspection (CEI) was conducted at the wastewater treatment plant serving Firehouse Grille & Pub. The purpose of the inspection was to observe the operation and maintenance of the plant, and to determine whether the facility has been in compliance with its National Pollutant Discharge Elimination System (NPDES) permit.

During the inspection, the following observations and/or deficiencies were noted:

1. The contents in the flow equalization tank were being properly aerated, but were almost white in color and extremely odorous. This office is wondering if possibly, the raw sewage is being held in the flow equalization tank too long. It is recommended your wastewater operator investigate if decreasing the detention time in the tank would help eliminate the obnoxious odors.
2. The mixed liquor in the extended aeration tank was being properly aerated, was the appropriate chocolate brown color, and was not odorous.
3. The surface sand filter was flooded almost to the top with partially treated wastewater. The flooded sand filters contained floating pinfloc and lots of brown and black solids. There was a sump pump present in the surface sand filter, which appears to be utilized for pumping the wastewater off the sand filter and over to the disinfection tank. Please be advised that bypassing of the surface sand filter is not permitted.
4. The disinfection tank appeared to contain pinfloc and white foam, rather than clear effluent.


The last time this office spoke with your plant's technical operator, Robert Ernsberger, it was understood that the surface sand filters had the wrong specification of sand. The entire sand filter was to be rehabilitated, and the proper sand was to be installed. Has this rehabilitation project taken place yet?

FIREHOUSE GRILLE & PUB
MAY 10, 2012
PAGE 2 OF 2

Review of the electronic Discharge Monitoring Reports (eDMRs) reported for your plant from April 2011 through March 2012 revealed only one suspended solids concentration violation.

In conclusion, this office directs that your certified WWTP operator provide a written explanation and correction plan concerning the above-mentioned deficiencies. If you have any questions concerning this letter, please contact this office at (330) 963-1151.

Sincerely,



Jennifer S. Bennage
Environmental Engineer
Division of Surface Water

JSB/cs

cc: Bob Hasenyager, Summit County Health Dept.
Dana Eldredge, Firehouse Grille & Pub
Robert Ernsberger

7011 0470 0002 3496 2181

U.S. Postal Service™	
CERTIFIED MAIL™ RECEIPT	
<i>(Domestic Mail Only; No Insurance Coverage Provided)</i>	
For delivery information visit our website at www.usps.com	
OFFICIAL USE	
Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$
Postmark Here	
Sent To	
Street, Apt. No., or PO Box No.	
City, State, ZIP+4	
PS Form 3800, August 2006	
See Reverse for Instructions	

Ohio


Environmental Protection Agency

Northeast District Office
2110 East Aurora Road
Twinsburg, OH 44087-1924

CERTIFIED MAIL



7011 0470 0002 3496 2181



UNITED STATES POSTAGE
PITNEY BOWES
02 1M \$ 05.75⁰⁰
0008007203 MAY 10 2012
MAILED FROM ZIP CODE 44087

RECEIVED

JUN 05 2012

OHIO EPA NEDO

Mr. Tony Jaber
3560 Hubert Avenue
Mogadore, OH 44260

1st NOTICE
2nd NOTICE 5-17
RETURNED 5-24

NIXIE 443 DE 1 00 06/02/12
RETURN TO SENDER
UNCLAIMED
UNABLE TO FORWARD
BC: 44087192410 *1673-02230-10-42

44260410460002

PS Form 3811, February 2004
Domestic Return Receipt
10255-02-M-1540

2. Article Number (Transfer from service label)
7011 0470 0002 3496 2181
5/10/12

1. Article Addressed to:
Mr. Tony Jaber
3560 Hubert Avenue
Mogadore, OH 44260

3. Service Type
 Certified Mail
 Express Mail
 Registered
 Return Receipt for Merchandise
 Insured Mail
 C.O.D.

4. Restricted Delivery? (Extra Fee)
 Yes
 No

D. Is delivery address different from item 1? Yes No
 If YES, enter delivery address below:

B. Received by (Printed Name)
C. Date of Delivery

A. Signature Agent Addressee

SENDER: COMPLETE THIS SECTION
COMPLETE THIS SECTION ON DELIVERY

PLACE STICKER AT TOP OF ENVELOPE TO THE RIGHT

