



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

June 11, 2012

RE: COLUMBIANA COUNTY  
CRESTVIEW SCHOOLS  
NPDES PERMIT NO. 3PT00059  
CRESTVIEW SCHOOLS WWTP  
44100 CRESTVIEW ROAD

Mr. John Dilling, Superintendent  
Crestview Schools  
44100 Crestview Road  
Columbiana, OH 44408

Dear Mr. Dilling:

On May 22, 2012, this writer conducted an inspection of Crestview Schools Wastewater Treatment Plant, located at 44100 Crestview Road. Representing the school during the inspection was Mr. Jay Radman, Maintenance Supervisor. The purpose of the inspection was to review the water pollution control facilities and evaluate compliance with the facility's National Pollutant Discharge Elimination System (NPDES) permit prior to drafting the renewal permit. The following was observed at the time of the inspection:

- 1) The facility appeared well maintained and well operated. The maintenance supervisor is currently providing excellent operational supervision. A review of the monthly operating report data from January 2009 through April 2012 indicated there were only three effluent violations of the NPDES permit during that time period.
- 2) At the time of the inspection, all treatment processes appeared satisfactory. The aeration tanks had a good color, and the clarifiers appeared to be producing a satisfactory effluent. The effluent appeared satisfactory as it discharged to Little Bull Creek.

Should you have any comments or concerns regarding this letter, please feel free to contact me at (330) 963-1193.

Respectfully,

Joseph E. Trocchio, P.E.  
Environmental Engineer  
Division of Surface Water

JET/cs

cc: Jay Radman

File: SemiPublic/Columbiana Count/Fairfield Township/Crestview Wastewater Treatment Plant