



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 13, 2012

Locust Ridge Nursing Home
12745 Elm Corner Road
Williamsburg, OH 45176

**RE: Locust Ridge Nursing Home Inc. – 1PX00059*CD
Notice of Violation**

Dear Permittee:

A compliance review was conducted on your Discharge Monitoring Report (DMR) submitted on June 11, 2012. As detailed at the end of this letter, screening of your submitted DMR has identified compliance issues.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at Joshua.Jackson@epa.state.oh.us.

Respectfully,

Joshua Jackson
Environmental Specialist II
Division of Surface Water

JJ/tf

ec: jvanharlingen@h2oco.net

Environmental Protection Agency

Governor
Lt. Governor
Director

Notice of Violation Report

Facility: Locust Ridge Nursing Home Inc

Permit No.: 1PX00059*CD

Report Period: May 2012

Date Received: 6/11/2012

...
001	Limit	5/14/2012	00300	Dissolved Oxygen	Daily Conc.	6.0	4.27
001	Limit	5/14/2012	00400	pH	Daily Conc.	6.5	6.1
001	Limit	5/1/2012	00530	Total Suspended Solids	Monthly Conc.	12	95.
001	Limit	5/1/2012	00530	Total Suspended Solids	Monthly Load	0.455	1.02479
001	Limit	5/8/2012	00530	Total Suspended Solids	Weekly Conc.	18	95.
001	Limit	5/8/2012	00530	Total Suspended Solids	Weekly Load	0.682	1.02479
001	Limit	5/1/2012	00610	Nitrogen, Ammonia (NH3)	Monthly Conc.	1.0	7.29
001	Limit	5/1/2012	00610	Nitrogen, Ammonia (NH3)	Monthly Load	0.0379	.07864
001	Limit	5/8/2012	00610	Nitrogen, Ammonia (NH3)	Weekly Conc.	1.5	7.29
001	Limit	5/8/2012	00610	Nitrogen, Ammonia (NH3)	Weekly Load	0.0568	.07864
001	Code	5/14/2012	31648	E. coli			AK