



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

June 18, 2012

RE: WAYNE COUNTY
EASTWOOD WWTP
NPDES NO. 3PG00133

Wayne County Commissioners
428 West Liberty Street
Wooster, Ohio 44691

Dear Commissioners:

This writer conducted a compliance evaluation inspection of the Eastwood Waste Water Treatment Works on June 13, 2012. Present during the inspection was Steve Wolf, Operator, Wayne County Sewer.

The existing sewage treatment system consists of an influent pump station, mechanical bar screen, flow equalization tank, followed by a 160,000-gpd membrane bioreactor, ultraviolet disinfection system. The system discharges to unnamed tributary of Little Sugar Creek.

At the time of the inspection, the treatment plant was in good operation and maintenance condition.

The mixed liquor in the aeration tank had a good color and the system was producing what appeared to be a good quality effluent.


A review of your self-monitoring reports covering the period July 2010 through May 2012 revealed the following effluent violations:

Permit No	Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PG00133*DD	September 2010	001	Phosphorus, Total (P)	30D Conc	1.0	1.73	9/1/2010
3PG00133*DD	September 2010	001	Phosphorus, Total (P)	7D Conc	1.5	1.73	9/1/2010
3PG00133*DD	August 2010	001	CBOD 5 day	7D Conc	15	22.5	8/8/2010
3PG00133*DD	August 2010	001	Phosphorus, Total (P)	30D Conc	1.0	1.71	8/1/2010
3PG00133*DD	August 2010	001	Phosphorus, Total (P)	7D Conc	1.5	1.71	8/1/2010
3PG00133*DD	November 2010	001	Phosphorus, Total (P)	30D Conc	1.0	1.45	11/1/2010
3PG00133*DD	October 2010	001	CBOD 5 day	7D Conc	15	17.1	10/1/2010
3PG00133*DD	October 2010	001	Phosphorus, Total (P)	30D Conc	1.0	1.55	10/1/2010
3PG00133*DD	October 2010	001	Phosphorus, Total (P)	7D Conc	1.5	1.55	10/1/2010

EASTWOOD WWTP
JUNE 18, 2012
PAGE 2 OF 2

Overall, the results of the inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Sincerely,



Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/cs

cc: Terry West, Superintendent, Wayne County Sewer

File: Public/Permit Compliance