



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

June 14, 2012

RE: STARK COUNTY
LAWRENCE TOWNSHIP
TOP O HILL MHP
4287 MANCHESTER AVE.
NPDES NO. 3PV00099

Mr. Jacob Grimm
Top O Hill MHP
6408 S. Main Street
Clinton, OH 44216

Dear Mr. Grimm:

On June 13, 2012 a compliance evaluation inspection (CEI) was conducted by this writer of the wastewater treatment system serving the above referenced facility.

At the time of the inspection, the treatment plant was found to be operating. It appeared all the components were working properly. The treatment system was producing a clear effluent of satisfactory quality.

A review of your Discharge Monitoring Reports (DMRs) covering the period November 2010 through May 2012 revealed the following effluent violations:

Permit No	Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PV00099*BD	November 2011	Total Suspended Solids	30D Conc	12	35.	11/1/2011
3PV00099*BD	November 2011	Total Suspended Solids	30D Qty	0.41	1.07305	11/1/2011
3PV00099*BD	November 2011	Nitrogen, Ammonia (NH3)	30D Conc	3.0	5.83	11/1/2011
3PV00099*BD	November 2011	Nitrogen, Ammonia (NH3)	30D Qty	0.10	.17874	11/1/2011
3PV00099*BD	November 2011	Total Suspended Solids	7D Conc	18	35.	11/8/2011
3PV00099*BD	November 2011	Total Suspended Solids	7D Qty	0.61	1.07305	11/8/2011
3PV00099*BD	November 2011	Nitrogen, Ammonia (NH3)	7D Conc	4.5	5.83	11/8/2011
3PV00099*BD	November 2011	Nitrogen, Ammonia (NH3)	7D Qty	0.15	.17874	11/8/2011
3PV00099*BD	November 2011	CBOD 5 day	1D Conc	15	4.8	11/14/2011

The renewal National Pollutant Discharge Elimination System (NPDES) permit for this facility will be public noticed in the near future. You will have 30 days from the date of public notice to submit written comments to Ohio EPA regarding the draft permit.

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Sincerely,

Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/ cs

cc: Stark County Health Department, Attn: Todd Ascani
File: Semi-Public/Top O Hill MHP