



**Environmental  
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

June 18, 2012

RE: WAYNE COUNTY  
EAST UNION TWP  
WHISPERING PINES MHP  
NPDES #3PV00101

Mr. Joseph LaMonica  
Whispering Pines MHP  
6658 Palmer Drive  
Canton, Ohio 44718

Dear Mr. LaMonica:

On June 13, 2012, this writer conducted an inspection of the wastewater treatment plant serving the Whispering Pines MHP. The intent of the inspection was to evaluate the compliance, operations and maintenance of the treatment system.

At the time of the inspection, the treatment plant was in operation. The mixed liquor in the aeration tank had a dark brown color. The blowers and pumps were operating. The sand filter beds were covered with excessive vegetation. The beds should be clean and raked as soon as possible.

A review of your Discharge Monitoring Reports (DMRs) covering the period June 2011 through May 2012 revealed the following effluent violations:


Permit No	Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PV00101*BD	August 2011	001	Nitrogen, Ammonia (NH3	30D Conc	1.0	3.74	8/1/2011
3PV00101*BD	August 2011	001	Nitrogen, Ammonia (NH3	30D Qty	0.045	.15571	8/1/2011
3PV00101*BD	August 2011	001	Nitrogen, Ammonia (NH3	1D Conc	1.5	3.74	8/23/2011
3PV00101*BD	August 2011	001	Nitrogen, Ammonia (NH3	1D Qty	0.068	.15571	8/23/2011
3PV00101*BD	September 2011	001	Nitrogen, Ammonia (NH3	30D Qty	0.045	18.6222	9/1/2011
3PV00101*BD	September 2011	001	Nitrogen, Ammonia (NH3	1D Qty	0.068	18.6222	9/16/2011
3PV00101*BD	February 2012	001	Nitrogen, Ammonia (NH3	30D Conc	3.0	3.19	2/1/2012
3PV00101*BD	February 2012	001	Nitrogen, Ammonia (NH3	30D Qty	0.14	.14489	2/1/2012

The renewal NPDES permit for this facility will be public noticed in the near future. You will have 30 days from the date of public notice to submit written comments to Ohio EPA regarding the draft permit.

MR. JOSEPH LAMONICA  
WHISPERING PINES MHP  
JUNE 18, 2012  
PAGE 2

Should you have any comments or questions regarding this letter, please contact this office at (330) 963-1255.

Respectfully,

A handwritten signature in black ink, appearing to read 'T. Surrena', with a long horizontal flourish extending to the right.

Todd M. Surrena  
Engineering Geologist  
Division of Surface Water

TMS:bo

cc: Wayne County Health Department

File: Semi-Public/Wayne/E. Union Twp/Whispering Pines MHP